

FOIA Request (Lab results 8/1/2015 to Present)

Bernice Brewer <bbrewer910@gmail.com>

Tue 9/27/2016 4:01 PM

16-9-27

To: Sherry Jasinski <sjasinski@saukville.org>;

Dear Sherri

Under the Freedom of Information Act, I am seeking all lab slips for water testing of Wells 1, 2 and 3 for the above mention dates. Please include all results for vinyl Chloride. Please provide copies of lab slips.

Your prompt attention to this matter is appreciated. Your response can be sent to bbrewer910@gmail.com. If you have questions, please call me at 773983 7137.

Bernice Brewer

KT 11-341



21801 Torrence Ave., Sauk Village, IL 60411 - Phone (708) 758-3330 - (708) 758-1634


Bernice Brewer

Date: 9/29/16

Re: FOIA REQUEST 2016-9-27

As you requested the vinyl chloride results from 8/1/15 to present.

Sincerely,

Kevin Weller 
Director of Public Works



Report Date: August 12, 2015

WorkOrder: 1508154

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- B Analyte detected in the associated Method Blank
- c Analyte not in SLI scope of accreditation
- C Value is below Minimum Concentration Limit
- E Estimated, detected above quantitation range
- G Refer to case narrative page for specific comments
- H Holding times for preparation or analysis exceeded
- J Analyte detected below quantitation limit (QL)
- N Tentatively identified compound
- ND Not Detected at the Reporting Limit
- P Present
- R RPD outside accepted recovery limits
- S Spike Recovery outside accepted recovery limits
- W Sample container temperature is out of limit as specified at testcode

SUBURBAN LABORATORIES, Inc.

1950 S. Batavia Ave., Suite 150, Geneva, IL 60134 (708) 544-3260



Laboratory Results

Client: Sauk Village Water Department

Report Date: August 12, 2015

Project: Volatile Organic Compounds

Workorder: 1508154

Client Sample ID: TP01

Matrix: Drinking Water

Lab ID: 1508154-001

Date Received: 8/4/2015 15:50 PM

Collection Date: 8/4/2015 11:05 AM

Parameter	Result	MCL	Report Limit	Qual	Units	DF	Date Analyzed	BatchID
VOLATILE ORGANIC COMPOUNDS (Regulated)			Method: EPA-524.2-4.1. 1995			Analyst: ks		
Benzene	ND	5.00	0.500		µg/L	1	8/5/2015 6:05 PM	R62549
Carbon tetrachloride	ND	5.00	0.500		µg/L	1	8/5/2015 6:05 PM	R62549
Chlorobenzene	ND	100	0.500		µg/L	1	8/5/2015 6:05 PM	R62549
1,4-Dichlorobenzene	ND	75.0	0.500		µg/L	1	8/5/2015 6:05 PM	R62549
1,2-Dichlorobenzene	ND	600	0.500		µg/L	1	8/5/2015 6:05 PM	R62549
1,2-Dichloroethane	ND	5.00	0.500		µg/L	1	8/5/2015 6:05 PM	R62549
1,1-Dichloroethene	ND	7.00	0.500		µg/L	1	8/5/2015 6:05 PM	R62549
cis-1,2-Dichloroethene	ND	70.0	0.500		µg/L	1	8/5/2015 6:05 PM	R62549
trans-1,2-Dichloroethene	ND	100	0.500		µg/L	1	8/5/2015 6:05 PM	R62549
1,2-Dichloropropane	ND	5.00	0.500		µg/L	1	8/5/2015 6:05 PM	R62549
Ethylbenzene	ND	700	0.500		µg/L	1	8/5/2015 6:05 PM	R62549
Methylene chloride	ND	5.00	0.500		µg/L	1	8/5/2015 6:05 PM	R62549
Styrene	ND	100	0.500		µg/L	1	8/5/2015 6:05 PM	R62549
Tetrachloroethene	ND	5.00	0.500		µg/L	1	8/5/2015 6:05 PM	R62549
Toluene	ND	1,000	0.500		µg/L	1	8/5/2015 6:05 PM	R62549
1,2,4-Trichlorobenzene	ND	70.0	0.500		µg/L	1	8/5/2015 6:05 PM	R62549
Trichloroethene	ND	5.00	0.500		µg/L	1	8/5/2015 6:05 PM	R62549
1,1,1-Trichloroethane	ND	200	0.500		µg/L	1	8/5/2015 6:05 PM	R62549
1,1,2-Trichloroethane	ND	5.00	0.500		µg/L	1	8/5/2015 6:05 PM	R62549
Vinyl chloride	ND	2.00	0.500		µg/L	1	8/5/2015 6:05 PM	R62549
Total Xylenes	ND	10,000	0.500		µg/L	1	8/5/2015 6:05 PM	R62549
Internal Quality Control Compounds								
Surr: 1,2-Dichlorobenzene-d4	83.6		70-130		%REC	1	8/5/2015 6:05 PM	R62549
Surr: 4-Bromofluorobenzene	89.6		70-130		%REC	1	8/5/2015 6:05 PM	R62549
VOLATILE ORGANIC COMPOUNDS (Unregulated)			Method: EPA-524.2-4.1. 1995			Analyst: ks		
Methyl tert-butyl ether	ND		0.500		µg/L	1	8/5/2015 6:05 PM	R62549

SUBURBAN LABORATORIES, Inc.

1950 S. Batavia Ave., Suite 150, Geneva, IL 60134 (708) 544-3260



Laboratory Results

Client: Sauk Village Water Department Project: Volatile Organic Compounds Client Sample ID: TP02 Lab ID: 1508154-003	Report Date: August 12, 2015 Workorder: 1508154 Matrix: Drinking Water Collection Date: 8/4/2015 8:10 AM Date Received: 8/4/2015 15:50 PM
---	--

Parameter	Result	MCL	Report Limit	Qual	Units	DF	Date Analyzed	BatchID	
VOLATILE ORGANIC COMPOUNDS (Regulated)		Method: EPA-524.2-4.1, 1995				Analyst: ks			
Benzene	ND	5.00	0.500		µg/L	1	8/5/2015 6:34 PM	R62549	
Carbon tetrachloride	ND	5.00	0.500		µg/L	1	8/5/2015 6:34 PM	R62549	
Chlorobenzene	ND	100	0.500		µg/L	1	8/5/2015 6:34 PM	R62549	
1,4-Dichlorobenzene	ND	75.0	0.500		µg/L	1	8/5/2015 6:34 PM	R62549	
1,2-Dichlorobenzene	ND	600	0.500		µg/L	1	8/5/2015 6:34 PM	R62549	
1,2-Dichloroethane	ND	5.00	0.500		µg/L	1	8/5/2015 6:34 PM	R62549	
1,1-Dichloroethene	ND	7.00	0.500		µg/L	1	8/5/2015 6:34 PM	R62549	
cis-1,2-Dichloroethene	ND	70.0	0.500		µg/L	1	8/5/2015 6:34 PM	R62549	
trans-1,2-Dichloroethene	ND	100	0.500		µg/L	1	8/5/2015 6:34 PM	R62549	
1,2-Dichloropropane	ND	5.00	0.500		µg/L	1	8/5/2015 6:34 PM	R62549	
Ethylbenzene	ND	700	0.500		µg/L	1	8/5/2015 6:34 PM	R62549	
Methylene chloride	ND	5.00	0.500		µg/L	1	8/5/2015 6:34 PM	R62549	
Styrene	ND	100	0.500		µg/L	1	8/5/2015 6:34 PM	R62549	
Tetrachloroethene	ND	5.00	0.500		µg/L	1	8/5/2015 6:34 PM	R62549	
Toluene	ND	1,000	0.500		µg/L	1	8/5/2015 6:34 PM	R62549	
1,2,4-Trichlorobenzene	ND	70.0	0.500		µg/L	1	8/5/2015 6:34 PM	R62549	
Trichloroethene	ND	5.00	0.500		µg/L	1	8/5/2015 6:34 PM	R62549	
1,1,1-Trichloroethane	ND	200	0.500		µg/L	1	8/5/2015 6:34 PM	R62549	
1,1,2-Trichloroethane	ND	5.00	0.500		µg/L	1	8/5/2015 6:34 PM	R62549	
Vinyl chloride	ND	2.00	0.500		µg/L	1	8/5/2015 6:34 PM	R62549	
Total Xylenes	ND	10,000	0.500		µg/L	1	8/5/2015 6:34 PM	R62549	
Internal Quality Control Compounds									
Surr: 1,2-Dichlorobenzene-d4	81.4		70-130		%REC	1	8/5/2015 6:34 PM	R62549	
Surr: 4-Bromofluorobenzene	87.4		70-130		%REC	1	8/5/2015 6:34 PM	R62549	
VOLATILE ORGANIC COMPOUNDS (Unregulated)		Method: EPA-524.2-4.1, 1995				Analyst: ks			
Methyl tert-butyl ether	ND		0.500		µg/L	1	8/5/2015 6:34 PM	R62549	

SUBURBAN LABORATORIES, Inc.

1950 S. Batavia Ave., Suite 150, Geneva, IL 60134 (708) 544-3260



Laboratory Results

Client: Sauk Village Water Department

Report Date: October 31, 2015

Project: Volatile Organic Compounds

Workorder: 1510G11

Client Sample ID: TP01

Matrix: Drinking Water

Lab ID: 1510G11-001

Date Received: 10/20/2015 15:50 PM

Collection Date: 10/20/2015 9:20 AM

Parameter	Result	MCL	Report Limit	Qual	Units	DF	Date Analyzed	BatchID
VOLATILE ORGANIC COMPOUNDS (Regulated)			Method: EPA-524.2-4.1. 1995	Analyst: rgb				
Benzene	ND	5.00	0.500		µg/L	1	10/23/2015 1:26 PM	R65502
Carbon tetrachloride	ND	5.00	0.500		µg/L	1	10/23/2015 1:26 PM	R65502
Chlorobenzene	ND	100	0.500		µg/L	1	10/23/2015 1:26 PM	R65502
1,4-Dichlorobenzene	ND	75.0	0.500		µg/L	1	10/23/2015 1:26 PM	R65502
1,2-Dichlorobenzene	ND	600	0.500		µg/L	1	10/23/2015 1:26 PM	R65502
1,2-Dichloroethane	ND	5.00	0.500		µg/L	1	10/23/2015 1:26 PM	R65502
1,1-Dichloroethene	ND	7.00	0.500		µg/L	1	10/23/2015 1:26 PM	R65502
cis-1,2-Dichloroethene	ND	70.0	0.500		µg/L	1	10/23/2015 1:26 PM	R65502
trans-1,2-Dichloroethene	ND	100	0.500		µg/L	1	10/23/2015 1:26 PM	R65502
1,2-Dichloropropane	ND	5.00	0.500		µg/L	1	10/23/2015 1:26 PM	R65502
Ethylbenzene	ND	700	0.500		µg/L	1	10/23/2015 1:26 PM	R65502
Methylene chloride	ND	5.00	0.500		µg/L	1	10/23/2015 1:26 PM	R65502
Styrene	ND	100	0.500		µg/L	1	10/23/2015 1:26 PM	R65502
Tetrachloroethene	ND	5.00	0.500		µg/L	1	10/23/2015 1:26 PM	R65502
Toluene	ND	1,000	0.500		µg/L	1	10/23/2015 1:26 PM	R65502
1,2,4-Trichlorobenzene	ND	70.0	0.500		µg/L	1	10/23/2015 1:26 PM	R65502
Trichloroethene	ND	5.00	0.500		µg/L	1	10/23/2015 1:26 PM	R65502
1,1,1-Trichloroethane	ND	200	0.500		µg/L	1	10/23/2015 1:26 PM	R65502
1,1,2-Trichloroethane	ND	5.00	0.500		µg/L	1	10/23/2015 1:26 PM	R65502
Vinyl chloride	ND	2.00	0.500		µg/L	1	10/23/2015 1:26 PM	R65502
Total Xylenes	ND	10,000	0.500		µg/L	1	10/23/2015 1:26 PM	R65502
Internal Quality Control Compounds								
Surr: 1,2-Dichlorobenzene-d4	95.6		70-130		%REC	1	10/23/2015 1:26 PM	R65502
Surr: 4-Bromofluorobenzene	97.2		70-130		%REC	1	10/23/2015 1:26 PM	R65502
VOLATILE ORGANIC COMPOUNDS (Unregulated)			Method: EPA-524.2-4.1. 1995	Analyst: rgb				
Methyl tert-butyl ether	ND		0.500		µg/L	1	10/23/2015 1:26 PM	R65502

SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150, Geneva, IL 60134 (708) 544-3260

Laboratory Results

Client: Sauk Village Water Department

Report Date: October 31, 2015

Project: Volatile Organic Compounds

Workorder: 1510G11

Client Sample ID: TP02

Matrix: Drinking Water

Lab ID: 1510G11-003

Date Received: 10/20/2015 15:50 PM

Collection Date: 10/20/2015 8:00 AM

Parameter	Result	MCL	Report Limit	Qual	Units	DF	Date Analyzed	BatchID
VOLATILE ORGANIC COMPOUNDS (Regulated)			Method: EPA-524.2-4.1, 1995	Analyst: rgb				
Benzene	ND	5.00	0.500		µg/L	1	10/23/2015 1:55 PM	R65502
Carbon tetrachloride	ND	5.00	0.500		µg/L	1	10/23/2015 1:55 PM	R65502
Chlorobenzene	ND	100	0.500		µg/L	1	10/23/2015 1:55 PM	R65502
1,4-Dichlorobenzene	ND	75.0	0.500		µg/L	1	10/23/2015 1:55 PM	R65502
1,2-Dichlorobenzene	ND	600	0.500		µg/L	1	10/23/2015 1:55 PM	R65502
1,2-Dichloroethane	ND	5.00	0.500		µg/L	1	10/23/2015 1:55 PM	R65502
1,1-Dichloroethene	ND	7.00	0.500		µg/L	1	10/23/2015 1:55 PM	R65502
cis-1,2-Dichloroethene	ND	70.0	0.500		µg/L	1	10/23/2015 1:55 PM	R65502
trans-1,2-Dichloroethene	ND	100	0.500		µg/L	1	10/23/2015 1:55 PM	R65502
1,2-Dichloropropane	ND	5.00	0.500		µg/L	1	10/23/2015 1:55 PM	R65502
Ethylbenzene	ND	700	0.500		µg/L	1	10/23/2015 1:55 PM	R65502
Methylene chloride	ND	5.00	0.500		µg/L	1	10/23/2015 1:55 PM	R65502
Styrene	ND	100	0.500		µg/L	1	10/23/2015 1:55 PM	R65502
Tetrachloroethene	ND	5.00	0.500		µg/L	1	10/23/2015 1:55 PM	R65502
Toluene	ND	1,000	0.500		µg/L	1	10/23/2015 1:55 PM	R65502
1,2,4-Trichlorobenzene	ND	70.0	0.500		µg/L	1	10/23/2015 1:55 PM	R65502
Trichloroethene	ND	5.00	0.500		µg/L	1	10/23/2015 1:55 PM	R65502
1,1,1-Trichloroethane	ND	200	0.500		µg/L	1	10/23/2015 1:55 PM	R65502
1,1,2-Trichloroethane	ND	5.00	0.500		µg/L	1	10/23/2015 1:55 PM	R65502
Vinyl chloride	ND	2.00	0.500		µg/L	1	10/23/2015 1:55 PM	R65502
Total Xylenes	ND	10,000	0.500		µg/L	1	10/23/2015 1:55 PM	R65502

Internal Quality Control Compounds

Surr: 1,2-Dichlorobenzene-d4	94.8		70-130		%REC	1	10/23/2015 1:55 PM	R65502
Surr: 4-Bromofluorobenzene	96.8		70-130		%REC	1	10/23/2015 1:55 PM	R65502

VOLATILE ORGANIC COMPOUNDS (Unregulated)

Method: EPA-524.2-4.1, 1995

Analyst: rgb

Methyl tert-butyl ether	ND		0.500		µg/L	1	10/23/2015 1:55 PM	R65502
-------------------------	----	--	-------	--	------	---	--------------------	--------

SUBURBAN LABORATORIES, Inc.

1950 S. Batavia Ave., Suite 150, Geneva, IL 60134 (708) 544-3260



Laboratory Results

Client: Sauk Village Water Department

Report Date: January 22, 2016

Project: Volatile Organic Compounds

Workorder: 1601969

Client Sample ID: TP01

Matrix: Drinking Water

Lab ID: 1601969-001

Date Received: 1/19/2016 16:00 PM

Collection Date: 1/19/2016 10:40 AM

Parameter	Result	MCL	Report Limit	Qual	Units	DF	Date Analyzed	BatchID
VOLATILE ORGANIC COMPOUNDS (Regulated)			Method: EPA-524.2-4.1, 1995			Analyst: rgb		
Benzene	ND	5.00	0.500		µg/L	1	1/21/2016 1:01 PM	R68200
Carbon tetrachloride	ND	5.00	0.500		µg/L	1	1/21/2016 1:01 PM	R68200
Chlorobenzene	ND	100	0.500		µg/L	1	1/21/2016 1:01 PM	R68200
1,4-Dichlorobenzene	ND	75.0	0.500		µg/L	1	1/21/2016 1:01 PM	R68200
1,2-Dichlorobenzene	ND	600	0.500		µg/L	1	1/21/2016 1:01 PM	R68200
1,2-Dichloroethane	ND	5.00	0.500		µg/L	1	1/21/2016 1:01 PM	R68200
1,1-Dichloroethene	ND	7.00	0.500		µg/L	1	1/21/2016 1:01 PM	R68200
cis-1,2-Dichloroethene	ND	70.0	0.500		µg/L	1	1/21/2016 1:01 PM	R68200
trans-1,2-Dichloroethene	ND	100	0.500		µg/L	1	1/21/2016 1:01 PM	R68200
1,2-Dichloropropane	ND	5.00	0.500		µg/L	1	1/21/2016 1:01 PM	R68200
Ethylbenzene	ND	700	0.500		µg/L	1	1/21/2016 1:01 PM	R68200
Methylene chloride	ND	5.00	0.500		µg/L	1	1/21/2016 1:01 PM	R68200
Styrene	ND	100	0.500		µg/L	1	1/21/2016 1:01 PM	R68200
Tetrachloroethene	ND	5.00	0.500		µg/L	1	1/21/2016 1:01 PM	R68200
Toluene	ND	1,000	0.500		µg/L	1	1/21/2016 1:01 PM	R68200
1,2,4-Trichlorobenzene	ND	70.0	0.500		µg/L	1	1/21/2016 1:01 PM	R68200
Trichloroethene	ND	5.00	0.500		µg/L	1	1/21/2016 1:01 PM	R68200
1,1,1-Trichloroethane	ND	200	0.500		µg/L	1	1/21/2016 1:01 PM	R68200
1,1,2-Trichloroethane	ND	5.00	0.500		µg/L	1	1/21/2016 1:01 PM	R68200
Vinyl chloride	ND	2.00	0.500		µg/L	1	1/21/2016 1:01 PM	R68200
Total Xylenes	ND	10,000	0.500		µg/L	1	1/21/2016 1:01 PM	R68200
Internal Quality Control Compounds								
Surr: 1,2-Dichlorobenzene-d4	102		70-130		%REC	1	1/21/2016 1:01 PM	R68200
Surr: 4-Bromofluorobenzene	99.8		70-130		%REC	1	1/21/2016 1:01 PM	R68200
VOLATILE ORGANIC COMPOUNDS (Unregulated)			Method: EPA-524.2-4.1, 1995			Analyst: rgb		
Methyl tert-butyl ether	ND		0.500		µg/L	1	1/21/2016 1:01 PM	R68200

SUBURBAN LABORATORIES, Inc.

1950 S. Batavia Ave., Suite 150, Geneva, IL 60134 (708) 544-3260



Laboratory Results

Client: Sauk Village Water Department

Report Date: January 22, 2016

Project: Volatile Organic Compounds

Workorder: 1601969

Client Sample ID: TP02

Matrix: Drinking Water

Lab ID: 1601969-003

Date Received: 1/19/2016 16:00 PM

Collection Date: 1/19/2016 8:06 AM

Parameter	Result	MCL	Report Limit	Qual	Units	DF	Date Analyzed	BatchID
VOLATILE ORGANIC COMPOUNDS (Regulated)			Method: EPA-524.2-4.1, 1995			Analyst: rgb		
Benzene	ND	5.00	0.500		µg/L	1	1/21/2016 1:29 PM	R68200
Carbon tetrachloride	ND	5.00	0.500		µg/L	1	1/21/2016 1:29 PM	R68200
Chlorobenzene	ND	100	0.500		µg/L	1	1/21/2016 1:29 PM	R68200
1,4-Dichlorobenzene	ND	75.0	0.500		µg/L	1	1/21/2016 1:29 PM	R68200
1,2-Dichlorobenzene	ND	600	0.500		µg/L	1	1/21/2016 1:29 PM	R68200
1,2-Dichloroethane	ND	5.00	0.500		µg/L	1	1/21/2016 1:29 PM	R68200
1,1-Dichloroethane	ND	7.00	0.500		µg/L	1	1/21/2016 1:29 PM	R68200
cis-1,2-Dichloroethane	ND	70.0	0.500		µg/L	1	1/21/2016 1:29 PM	R68200
trans-1,2-Dichloroethane	ND	100	0.500		µg/L	1	1/21/2016 1:29 PM	R68200
1,2-Dichloropropane	ND	5.00	0.500		µg/L	1	1/21/2016 1:29 PM	R68200
Ethylbenzene	ND	700	0.500		µg/L	1	1/21/2016 1:29 PM	R68200
Methylene chloride	ND	5.00	0.500		µg/L	1	1/21/2016 1:29 PM	R68200
Styrene	ND	100	0.500		µg/L	1	1/21/2016 1:29 PM	R68200
Tetrachloroethene	ND	5.00	0.500		µg/L	1	1/21/2016 1:29 PM	R68200
Toluene	ND	1,000	0.500		µg/L	1	1/21/2016 1:29 PM	R68200
1,2,4-Trichlorobenzene	ND	70.0	0.500		µg/L	1	1/21/2016 1:29 PM	R68200
Trichloroethene	ND	5.00	0.500		µg/L	1	1/21/2016 1:29 PM	R68200
1,1,1-Trichloroethane	ND	200	0.500		µg/L	1	1/21/2016 1:29 PM	R68200
1,1,2-Trichloroethane	ND	5.00	0.500		µg/L	1	1/21/2016 1:29 PM	R68200
Vinyl chloride	ND	2.00	0.500		µg/L	1	1/21/2016 1:29 PM	R68200
Total Xylenes	ND	10,000	0.500		µg/L	1	1/21/2016 1:29 PM	R68200
Internal Quality Control Compounds								
Surr: 1,2-Dichlorobenzene-d4	101		70-130		%REC	1	1/21/2016 1:29 PM	R68200
Surr: 4-Bromofluorobenzene	99.0		70-130		%REC	1	1/21/2016 1:29 PM	R68200
VOLATILE ORGANIC COMPOUNDS (Unregulated)			Method: EPA-524.2-4.1, 1995			Analyst: rgb		
Methyl tert-butyl ether	ND		0.500		µg/L	1	1/21/2016 1:29 PM	R68200

SUBURBAN LABORATORIES, Inc.

1950 S. Batavia Ave., Suite 150, Geneva, IL 60134 (708) 544-3260



Laboratory Results

Client: Sauk Village Water Department

Report Date: April 26, 2016

Project: Volatile Organic Compounds

Workorder: 1604C89

Client Sample ID: TP01

Matrix: Drinking Water

Lab ID: 1604C89-001

Date Received: 4/19/2016 16:30 PM

Collection Date: 4/19/2016 8:15 AM

Parameter	Result	MCL	Report Limit	Qual	Units	DF	Date Analyzed	BatchID	
VOLATILE ORGANIC COMPOUNDS (Regulated)		Method: EPA-524.2-4.1, 1995				Analyst: rgb			
Benzene	ND	5.00	0.500		µg/L	1	4/22/2016 10:37 AM	R71220	
Carbon tetrachloride	ND	5.00	0.500		µg/L	1	4/22/2016 10:37 AM	R71220	
Chlorobenzene	ND	100	0.500		µg/L	1	4/22/2016 10:37 AM	R71220	
1,4-Dichlorobenzene	ND	75.0	0.500		µg/L	1	4/22/2016 10:37 AM	R71220	
1,2-Dichlorobenzene	ND	600	0.500		µg/L	1	4/22/2016 10:37 AM	R71220	
1,2-Dichloroethane	ND	5.00	0.500		µg/L	1	4/22/2016 10:37 AM	R71220	
1,1-Dichloroethene	ND	7.00	0.500		µg/L	1	4/22/2016 10:37 AM	R71220	
cis-1,2-Dichloroethene	ND	70.0	0.500		µg/L	1	4/22/2016 10:37 AM	R71220	
trans-1,2-Dichloroethene	ND	100	0.500		µg/L	1	4/22/2016 10:37 AM	R71220	
1,2-Dichloropropane	ND	5.00	0.500		µg/L	1	4/22/2016 10:37 AM	R71220	
Ethylbenzene	ND	700	0.500		µg/L	1	4/22/2016 10:37 AM	R71220	
Methylene chloride	ND	5.00	0.500		µg/L	1	4/22/2016 10:37 AM	R71220	
Styrene	ND	100	0.500		µg/L	1	4/22/2016 10:37 AM	R71220	
Tetrachloroethene	ND	5.00	0.500		µg/L	1	4/22/2016 10:37 AM	R71220	
Toluene	ND	1,000	0.500		µg/L	1	4/22/2016 10:37 AM	R71220	
1,2,4-Trichlorobenzene	ND	70.0	0.500		µg/L	1	4/22/2016 10:37 AM	R71220	
Trichloroethene	ND	5.00	0.500		µg/L	1	4/22/2016 10:37 AM	R71220	
1,1,1-Trichloroethane	ND	200	0.500		µg/L	1	4/22/2016 10:37 AM	R71220	
1,1,2-Trichloroethane	ND	5.00	0.500		µg/L	1	4/22/2016 10:37 AM	R71220	
Vinyl chloride	ND	2.00	0.500		µg/L	1	4/22/2016 10:37 AM	R71220	
Total Xylenes	ND	10,000	0.500		µg/L	1	4/22/2016 10:37 AM	R71220	
<u>Internal Quality Control Compounds</u>									
Surr: 1,2-Dichlorobenzene-d4	75.8		70-130		%Rec	1	4/22/2016 10:37 AM	R71220	
Surr: 4-Bromofluorobenzene	79.6		70-130		%Rec	1	4/22/2016 10:37 AM	R71220	
VOLATILE ORGANIC COMPOUNDS (Unregulated)		Method: EPA-524.2-4.1, 1995				Analyst: rgb			
Methyl tert-butyl ether	ND		0.500		µg/L	1	4/22/2016 10:37 AM	R71220	

SUBURBAN LABORATORIES, Inc.

1950 S. Batavia Ave., Suite 150, Geneva, IL 60134 (708) 544-3260



Laboratory Results

Client: Sauk Village Water Department

Report Date: April 26, 2016

Project: Volatile Organic Compounds

Workorder: 1604C89

Client Sample ID: TP02

Matrix: Drinking Water

Lab ID: 1604C89-003

Date Received: 4/19/2016 16:30 PM

Collection Date: 4/19/2016 7:50 AM

Parameter	Result	MCL	Report Limit	Qual	Units	DF	Date Analyzed	BatchID	
VOLATILE ORGANIC COMPOUNDS (Regulated)		Method: EPA-524.2-4.1, 1995				Analyst: rgb			
Benzene	ND	5.00	0.500		µg/L	1	4/22/2016 11:05 AM	R71220	
Carbon tetrachloride	ND	5.00	0.500		µg/L	1	4/22/2016 11:05 AM	R71220	
Chlorobenzene	ND	100	0.500		µg/L	1	4/22/2016 11:05 AM	R71220	
1,4-Dichlorobenzene	ND	75.0	0.500		µg/L	1	4/22/2016 11:05 AM	R71220	
1,2-Dichlorobenzene	ND	600	0.500		µg/L	1	4/22/2016 11:05 AM	R71220	
1,2-Dichloroethane	ND	5.00	0.500		µg/L	1	4/22/2016 11:05 AM	R71220	
1,1-Dichloroethene	ND	7.00	0.500		µg/L	1	4/22/2016 11:05 AM	R71220	
cis-1,2-Dichloroethene	ND	70.0	0.500		µg/L	1	4/22/2016 11:05 AM	R71220	
trans-1,2-Dichloroethene	ND	100	0.500		µg/L	1	4/22/2016 11:05 AM	R71220	
1,2-Dichloropropane	ND	5.00	0.500		µg/L	1	4/22/2016 11:05 AM	R71220	
Ethylbenzene	ND	700	0.500		µg/L	1	4/22/2016 11:05 AM	R71220	
Methylene chloride	ND	5.00	0.500		µg/L	1	4/22/2016 11:05 AM	R71220	
Styrene	ND	100	0.500		µg/L	1	4/22/2016 11:05 AM	R71220	
Tetrachloroethene	ND	5.00	0.500		µg/L	1	4/22/2016 11:05 AM	R71220	
Toluene	ND	1,000	0.500		µg/L	1	4/22/2016 11:05 AM	R71220	
1,2,4-Trichlorobenzene	ND	70.0	0.500		µg/L	1	4/22/2016 11:05 AM	R71220	
Trichloroethene	ND	5.00	0.500		µg/L	1	4/22/2016 11:05 AM	R71220	
1,1,1-Trichloroethane	ND	200	0.500		µg/L	1	4/22/2016 11:05 AM	R71220	
1,1,2-Trichloroethane	ND	5.00	0.500		µg/L	1	4/22/2016 11:05 AM	R71220	
Vinyl chloride	ND	2.00	0.500		µg/L	1	4/22/2016 11:05 AM	R71220	
Total Xylenes	ND	10,000	0.500		µg/L	1	4/22/2016 11:05 AM	R71220	
Internal Quality Control Compounds									
Surr: 1,2-Dichlorobenzene-d4	78.2		70-130		%Rec	1	4/22/2016 11:05 AM	R71220	
Surr: 4-Bromofluorobenzene	81.6		70-130		%Rec	1	4/22/2016 11:05 AM	R71220	
VOLATILE ORGANIC COMPOUNDS (Unregulated)		Method: EPA-524.2-4.1, 1995				Analyst: rgb			
Methyl tert-butyl ether	ND		0.500		µg/L	1	4/22/2016 11:05 AM	R71220	



Suburban Laboratories, Inc.

1950 S. Batavia Ave., Suite 150, Geneva, IL 60134 (708) 544-3260

Laboratory Results

Client ID: Sauk Village Water Department

Report Date: June 30, 2016

Project Name: Volatile Organic Compounds

Workorder: 1606119

Client Sample ID: TP01

Matrix: DRINKING WATER

Lab ID: 1606119-005

Date Received: 06/21/2016 4:15 PM

Collection Date: 06/21/2016 9:20 AM

Parameter	Result	Report MCL Limit	Qual.	Units	Dilution Factor	Date Analyzed	Batch ID
VOLATILE ORGANIC COMPOUNDS (REGULATED)		Method: EPA-524.2-Rev R4.1			Analyst: rgb		
Benzene	ND	5.00 0.500		µg/L	1	06/22/2016 12:01 PM	R73286
Carbon tetrachloride	ND	5.00 0.500		µg/L	1	06/22/2016 12:01 PM	R73286
Chlorobenzene	ND	100 0.500		µg/L	1	06/22/2016 12:01 PM	R73286
1,4-Dichlorobenzene	ND	75.0 0.500		µg/L	1	06/22/2016 12:01 PM	R73286
1,2-Dichlorobenzene	ND	600 0.500		µg/L	1	06/22/2016 12:01 PM	R73286
1,2-Dichloroethane	ND	5.00 0.500		µg/L	1	06/22/2016 12:01 PM	R73286
1,1-Dichloroethene	ND	7.00 0.500		µg/L	1	06/22/2016 12:01 PM	R73286
cis-1,2-Dichloroethene	ND	70.0 0.500		µg/L	1	06/22/2016 12:01 PM	R73286
trans-1,2-Dichloroethene	ND	100 0.500		µg/L	1	06/22/2016 12:01 PM	R73286
1,2-Dichloropropane	ND	5.00 0.500		µg/L	1	06/22/2016 12:01 PM	R73286
Ethylbenzene	ND	700 0.500		µg/L	1	06/22/2016 12:01 PM	R73286
Methylene chloride	ND	5.00 0.500		µg/L	1	06/22/2016 12:01 PM	R73286
Styrene	ND	100 0.500		µg/L	1	06/22/2016 12:01 PM	R73286
Tetrachloroethene	ND	5.00 0.500		µg/L	1	06/22/2016 12:01 PM	R73286
Toluene	ND	1,000 0.500		µg/L	1	06/22/2016 12:01 PM	R73286
1,2,4-Trichlorobenzene	ND	70.0 0.500		µg/L	1	06/22/2016 12:01 PM	R73286
Trichloroethene	ND	5.00 0.500		µg/L	1	06/22/2016 12:01 PM	R73286
1,1,1-Trichloroethane	ND	200 0.500		µg/L	1	06/22/2016 12:01 PM	R73286
1,1,2-Trichloroethane	ND	5.00 0.500		µg/L	1	06/22/2016 12:01 PM	R73286
Vinyl chloride	ND	2.00 0.500		µg/L	1	06/22/2016 12:01 PM	R73286
Total Xylenes	ND	10,000 0.500		µg/L	1	06/22/2016 12:01 PM	R73286
<u>Internal Quality Control Compounds</u>							
SS: 1,2-Dichlorobenzene-d4	101	70-130		%Rec	1	06/22/2016 12:01 PM	R73286
SS: 4-Bromofluorobenzene	98.4	70-130		%Rec	1	06/22/2016 12:01 PM	R73286
VOLATILE ORGANIC COMPOUNDS (UNREGULATED)		Method: EPA-524.2-Rev 4.1, 1995			Analyst: rgb		
Methyl tert-butyl ether	ND	0.500		µg/L	1	06/22/2016 12:01 PM	R73286



Suburban Laboratories, Inc.

1950 S. Batavia Ave., Suite 150, Geneva, IL 60134 (708) 544-3260

Laboratory Results

Client ID: Sauk Village Water Department

Report Date: June 30, 2016

Project Name: Volatile Organic Compounds

Workorder: 1606119

Client Sample ID: WL20600

Matrix: DRINKING WATER

Lab ID: 1606119-007

Date Received: 06/21/2016 4:15 PM

Collection Date: 06/21/2016 9:25 AM

Parameter	Result	Report MCL	Limit	Qual.	Units	Dilution Factor	Date Analyzed	Batch ID
VOLATILE ORGANIC COMPOUNDS (REGULATED)			Method: EPA-524.2-Rev R4.1			Analyst: rgb		
Benzene	ND	5.00	0.500		µg/L	1	06/22/2016 2:04 PM	R73286
Carbon tetrachloride	ND	5.00	0.500		µg/L	1	06/22/2016 2:04 PM	R73286
Chlorobenzene	ND	100	0.500		µg/L	1	06/22/2016 2:04 PM	R73286
1,4-Dichlorobenzene	ND	75.0	0.500		µg/L	1	06/22/2016 2:04 PM	R73286
1,2-Dichlorobenzene	ND	600	0.500		µg/L	1	06/22/2016 2:04 PM	R73286
1,2-Dichloroethane	ND	5.00	0.500		µg/L	1	06/22/2016 2:04 PM	R73286
1,1-Dichloroethene	ND	7.00	0.500		µg/L	1	06/22/2016 2:04 PM	R73286
cis-1,2-Dichloroethene	ND	70.0	0.500		µg/L	1	06/22/2016 2:04 PM	R73286
trans-1,2-Dichloroethene	ND	100	0.500		µg/L	1	06/22/2016 2:04 PM	R73286
1,2-Dichloropropane	ND	5.00	0.500		µg/L	1	06/22/2016 2:04 PM	R73286
Ethylbenzene	ND	700	0.500		µg/L	1	06/22/2016 2:04 PM	R73286
Methylene chloride	ND	5.00	0.500		µg/L	1	06/22/2016 2:04 PM	R73286
Styrene	ND	100	0.500		µg/L	1	06/22/2016 2:04 PM	R73286
Tetrachloroethene	ND	5.00	0.500		µg/L	1	06/22/2016 2:04 PM	R73286
Toluene	ND	1,000	0.500		µg/L	1	06/22/2016 2:04 PM	R73286
1,2,4-Trichlorobenzene	ND	70.0	0.500		µg/L	1	06/22/2016 2:04 PM	R73286
Trichloroethene	ND	5.00	0.500		µg/L	1	06/22/2016 2:04 PM	R73286
1,1,1-Trichloroethane	ND	200	0.500		µg/L	1	06/22/2016 2:04 PM	R73286
1,1,2-Trichloroethane	ND	5.00	0.500		µg/L	1	06/22/2016 2:04 PM	R73286
Vinyl chloride	ND	2.00	0.500		µg/L	1	06/22/2016 2:04 PM	R73286
Total Xylenes	ND	10,000	0.500		µg/L	1	06/22/2016 2:04 PM	R73286
<u>Internal Quality Control Compounds</u>								
SS: 1,2-Dichlorobenzene-d4	103		70-130		%Rec	1	06/22/2016 2:04 PM	R73286
SS: 4-Bromofluorobenzene	98.6		70-130		%Rec	1	06/22/2016 2:04 PM	R73286
VOLATILE ORGANIC COMPOUNDS (UNREGULATED)			Method: EPA-524.2-Rev 4.1, 1995			Analyst: rgb		
Methyl tert-butyl ether	ND		0.500		µg/L	1	06/22/2016 2:04 PM	R73286



Suburban Laboratories, Inc.

1950 S. Batavia Ave., Suite 150, Geneva, IL 60134 (708) 544-3260

Laboratory Results

Client ID: Sauk Village Water Department

Report Date: June 30, 2016

Project Name: Volatile Organic Compounds

Workorder: 1606119

Client Sample ID: WL20601

Matrix: DRINKING WATER

Lab ID: 1606119-009

Date Received: 06/21/2016 4:15 PM

Collection Date: 06/21/2016 9:40 AM

Parameter	Result	Report MCL	Limit	Qual.	Units	Dilution Factor	Date Analyzed	Batch ID
VOLATILE ORGANIC COMPOUNDS (REGULATED)			Method: EPA-524.2-Rev R4.1			Analyst: rgb		
Benzene	ND	5.00	0.500		µg/L	1	06/22/2016 2:32 PM	R73286
Carbon tetrachloride	ND	5.00	0.500		µg/L	1	06/22/2016 2:32 PM	R73286
Chlorobenzene	ND	100	0.500		µg/L	1	06/22/2016 2:32 PM	R73286
1,4-Dichlorobenzene	ND	75.0	0.500		µg/L	1	06/22/2016 2:32 PM	R73286
1,2-Dichlorobenzene	ND	600	0.500		µg/L	1	06/22/2016 2:32 PM	R73286
1,2-Dichloroethane	ND	5.00	0.500		µg/L	1	06/22/2016 2:32 PM	R73286
1,1-Dichloroethene	ND	7.00	0.500		µg/L	1	06/22/2016 2:32 PM	R73286
cis-1,2-Dichloroethene	ND	70.0	0.500		µg/L	1	06/22/2016 2:32 PM	R73286
trans-1,2-Dichloroethene	ND	100	0.500		µg/L	1	06/22/2016 2:32 PM	R73286
1,2-Dichloropropane	ND	5.00	0.500		µg/L	1	06/22/2016 2:32 PM	R73286
Ethylbenzene	ND	700	0.500		µg/L	1	06/22/2016 2:32 PM	R73286
Methylene chloride	ND	5.00	0.500		µg/L	1	06/22/2016 2:32 PM	R73286
Styrene	ND	100	0.500		µg/L	1	06/22/2016 2:32 PM	R73286
Tetrachloroethene	ND	5.00	0.500		µg/L	1	06/22/2016 2:32 PM	R73286
Toluene	ND	1,000	0.500		µg/L	1	06/22/2016 2:32 PM	R73286
1,2,4-Trichlorobenzene	ND	70.0	0.500		µg/L	1	06/22/2016 2:32 PM	R73286
Trichloroethene	ND	5.00	0.500		µg/L	1	06/22/2016 2:32 PM	R73286
1,1,1-Trichloroethane	ND	200	0.500		µg/L	1	06/22/2016 2:32 PM	R73286
1,1,2-Trichloroethane	ND	5.00	0.500		µg/L	1	06/22/2016 2:32 PM	R73286
Vinyl chloride	ND	2.00	0.500		µg/L	1	06/22/2016 2:32 PM	R73286
Total Xylenes	ND	10,000	0.500		µg/L	1	06/22/2016 2:32 PM	R73286
<u>Internal Quality Control Compounds</u>								
SS: 1,2-Dichlorobenzene-d4	104		70-130		%Rec	1	06/22/2016 2:32 PM	R73286
SS: 4-Bromofluorobenzene	98.6		70-130		%Rec	1	06/22/2016 2:32 PM	R73286
VOLATILE ORGANIC COMPOUNDS (UNREGULATED)			Method: EPA-524.2-Rev 4.1, 1995			Analyst: rgb		
Methyl tert-butyl ether	ND		0.500		µg/L	1	06/22/2016 2:32 PM	R73286



Suburban Laboratories, Inc.

1950 S. Baravia Ave., Suite 150. Geneva, IL 60134 (708) 544-3260

Laboratory Results

Client ID: Sauk Village Water Department

Report Date: June 30, 2016

Project Name: Volatile Organic Compounds

Workorder: 1606119

Client Sample ID: TP02

Matrix: DRINKING WATER

Lab ID: 1606119-001

Date Received: 06/21/2016 4:15 PM

Collection Date: 06/21/2016 8:07 AM

Parameter	Result	MCL	Report Limit	Qual.	Units	Dilution Factor	Date Analyzed	Batch ID
VOLATILE ORGANIC COMPOUNDS (REGULATED)			Method: EPA-524.2-Rev R4.1			Analyst: rgb		
Benzene	ND	5.00	0.500		µg/L	1	06/22/2016 11:05 AM	R73286
Carbon tetrachloride	ND	5.00	0.500		µg/L	1	06/22/2016 11:05 AM	R73286
Chlorobenzene	ND	100	0.500		µg/L	1	06/22/2016 11:05 AM	R73286
1,4-Dichlorobenzene	ND	75.0	0.500		µg/L	1	06/22/2016 11:05 AM	R73286
1,2-Dichlorobenzene	ND	600	0.500		µg/L	1	06/22/2016 11:05 AM	R73286
1,2-Dichloroethane	ND	5.00	0.500		µg/L	1	06/22/2016 11:05 AM	R73286
1,1-Dichloroethene	ND	7.00	0.500		µg/L	1	06/22/2016 11:05 AM	R73286
cis-1,2-Dichloroethene	ND	70.0	0.500		µg/L	1	06/22/2016 11:05 AM	R73286
trans-1,2-Dichloroethene	ND	100	0.500		µg/L	1	06/22/2016 11:05 AM	R73286
1,2-Dichloropropane	ND	5.00	0.500		µg/L	1	06/22/2016 11:05 AM	R73286
Ethylbenzene	ND	700	0.500		µg/L	1	06/22/2016 11:05 AM	R73286
Methylene chloride	ND	5.00	0.500		µg/L	1	06/22/2016 11:05 AM	R73286
Styrene	ND	100	0.500		µg/L	1	06/22/2016 11:05 AM	R73286
Tetrachloroethene	ND	5.00	0.500		µg/L	1	06/22/2016 11:05 AM	R73286
Toluene	ND	1,000	0.500		µg/L	1	06/22/2016 11:05 AM	R73286
1,2,4-Trichlorobenzene	ND	70.0	0.500		µg/L	1	06/22/2016 11:05 AM	R73286
Trichloroethene	ND	5.00	0.500		µg/L	1	06/22/2016 11:05 AM	R73286
1,1,1-Trichloroethane	ND	200	0.500		µg/L	1	06/22/2016 11:05 AM	R73286
1,1,2-Trichloroethane	ND	5.00	0.500		µg/L	1	06/22/2016 11:05 AM	R73286
Vinyl chloride	ND	2.00	0.500		µg/L	1	06/22/2016 11:05 AM	R73286
Total Xylenes	ND	10,000	0.500		µg/L	1	06/22/2016 11:05 AM	R73286
<u>Internal Quality Control Compounds</u>								
SS: 1,2-Dichlorobenzene-d4	96.0		70-130		%Rec	1	06/22/2016 11:05 AM	R73286
SS: 4-Bromofluorobenzene	94.0		70-130		%Rec	1	06/22/2016 11:05 AM	R73286
VOLATILE ORGANIC COMPOUNDS (UNREGULATED)			Method: EPA-524.2-Rev 4.1, 1995			Analyst: rgb		
Methyl tert-butyl ether	ND		0.500		µg/L	1	06/22/2016 11:05 AM	R73286



Suburban Laboratories, Inc.

1950 S. Batavia Ave., Suite 150, Geneva, IL 60134 (708) 544-3260

Laboratory Results

Client ID: Sauk Village Water Department

Report Date: June 30, 2016

Project Name: Volatile Organic Compounds

Workorder: 1606119

Client Sample ID: WL20602

Matrix: DRINKING WATER

Lab ID: 1606119-003

Date Received: 06/21/2016 4:15 PM

Collection Date: 06/21/2016 8:01 AM

Parameter	Result	Report		Qual.	Units	Dilution		Batch ID
		MCL	Limit			Factor	Date Analyzed	
VOLATILE ORGANIC COMPOUNDS (REGULATED)			Method: EPA-524.2-Rev R4.1			Analyst: rgb		
Benzene	ND	5.00	0.500	G	µg/L	1	06/22/2016 11:33 AM	R73286
Carbon tetrachloride	ND	5.00	0.500	G	µg/L	1	06/22/2016 11:33 AM	R73286
Chlorobenzene	ND	100	0.500	G	µg/L	1	06/22/2016 11:33 AM	R73286
1,4-Dichlorobenzene	ND	75.0	0.500	G	µg/L	1	06/22/2016 11:33 AM	R73286
1,2-Dichlorobenzene	ND	600	0.500	G	µg/L	1	06/22/2016 11:33 AM	R73286
1,2-Dichloroethane	ND	5.00	0.500	G	µg/L	1	06/22/2016 11:33 AM	R73286
1,1-Dichloroethene	ND	7.00	0.500	G	µg/L	1	06/22/2016 11:33 AM	R73286
cis-1,2-Dichloroethene	0.610	70.0	0.500	G	µg/L	1	06/22/2016 11:33 AM	R73286
trans-1,2-Dichloroethene	ND	100	0.500	G	µg/L	1	06/22/2016 11:33 AM	R73286
1,2-Dichloropropane	ND	5.00	0.500	G	µg/L	1	06/22/2016 11:33 AM	R73286
Ethylbenzene	ND	700	0.500	G	µg/L	1	06/22/2016 11:33 AM	R73286
Methylene chloride	ND	5.00	0.500	G	µg/L	1	06/22/2016 11:33 AM	R73286
Styrene	ND	100	0.500	G	µg/L	1	06/22/2016 11:33 AM	R73286
Tetrachloroethene	ND	5.00	0.500	G	µg/L	1	06/22/2016 11:33 AM	R73286
Toluene	ND	1,000	0.500	G	µg/L	1	06/22/2016 11:33 AM	R73286
1,2,4-Trichlorobenzene	ND	70.0	0.500	G	µg/L	1	06/22/2016 11:33 AM	R73286
Trichloroethene	ND	5.00	0.500	G	µg/L	1	06/22/2016 11:33 AM	R73286
1,1,1-Trichloroethane	ND	200	0.500	G	µg/L	1	06/22/2016 11:33 AM	R73286
1,1,2-Trichloroethane	ND	5.00	0.500	G	µg/L	1	06/22/2016 11:33 AM	R73286
Vinyl chloride	5.38	2.00	0.500	*G	µg/L	1	06/22/2016 11:33 AM	R73286
Total Xylenes	ND	10,000	0.500	G	µg/L	1	06/22/2016 11:33 AM	R73286
<u>Internal Quality Control Compounds</u>								
SS: 1,2-Dichlorobenzene-d4	105		70-130	G	%Rec	1	06/22/2016 11:33 AM	R73286
SS: 4-Bromofluorobenzene	98.4		70-130	G	%Rec	1	06/22/2016 11:33 AM	R73286
VOLATILE ORGANIC COMPOUNDS (UNREGULATED)			Method: EPA-524.2-Rev 4.1, 1995			Analyst: rgb		
Methyl tert-butyl ether	ND		0.500	G	µg/L	1	06/22/2016 11:33 AM	R73286



Suburban Laboratories, Inc.

1950 S. Batavia Ave., Suite 150, Geneva, IL 60134 (708) 544-3260

Laboratory Results

Client ID: Sauk Village Water Department

Report Date: July 13, 2016

Project Name: Volatile Organic Compounds

Workorder: 1607093

Client Sample ID: TP01

Matrix: DRINKING WATER

Lab ID: 1607093-001

Date Received: 07/05/2016 4:40 PM

Collection Date: 07/05/2016 8:20 AM

Parameter	Result	MCL	Report Limit	Qual.	Units	Dilution Factor	Date Analyzed	Batch ID
VOLATILE ORGANIC COMPOUNDS (REGULATED)			Method: EPA-524.2-Rev R4.1			Analyst: rgb		
Benzene	ND	5.00	0.500		µg/L	1	07/06/2016 1:26 PM	R73718
Carbon tetrachloride	ND	5.00	0.500		µg/L	1	07/06/2016 1:26 PM	R73718
Chlorobenzene	ND	100	0.500		µg/L	1	07/06/2016 1:26 PM	R73718
1,4-Dichlorobenzene	ND	75.0	0.500		µg/L	1	07/06/2016 1:26 PM	R73718
1,2-Dichlorobenzene	ND	600	0.500		µg/L	1	07/06/2016 1:26 PM	R73718
1,2-Dichloroethane	ND	5.00	0.500		µg/L	1	07/06/2016 1:26 PM	R73718
1,1-Dichloroethane	ND	7.00	0.500		µg/L	1	07/06/2016 1:26 PM	R73718
cis-1,2-Dichloroethene	ND	70.0	0.500		µg/L	1	07/06/2016 1:26 PM	R73718
trans-1,2-Dichloroethene	ND	100	0.500		µg/L	1	07/06/2016 1:26 PM	R73718
1,2-Dichloropropane	ND	5.00	0.500		µg/L	1	07/06/2016 1:26 PM	R73718
Ethylbenzene	ND	700	0.500		µg/L	1	07/06/2016 1:26 PM	R73718
Methylene chloride	ND	5.00	0.500		µg/L	1	07/06/2016 1:26 PM	R73718
Styrene	ND	100	0.500		µg/L	1	07/06/2016 1:26 PM	R73718
Tetrachloroethene	ND	5.00	0.500		µg/L	1	07/06/2016 1:26 PM	R73718
Toluene	ND	1,000	0.500		µg/L	1	07/06/2016 1:26 PM	R73718
1,2,4-Trichlorobenzene	ND	70.0	0.500		µg/L	1	07/06/2016 1:26 PM	R73718
Trichloroethene	ND	5.00	0.500		µg/L	1	07/06/2016 1:26 PM	R73718
1,1,1-Trichloroethane	ND	200	0.500		µg/L	1	07/06/2016 1:26 PM	R73718
1,1,2-Trichloroethane	ND	5.00	0.500		µg/L	1	07/06/2016 1:26 PM	R73718
Vinyl chloride	ND	2.00	0.500		µg/L	1	07/06/2016 1:26 PM	R73718
Total Xylenes	ND	10,000	0.500		µg/L	1	07/06/2016 1:26 PM	R73718
<u>Internal Quality Control Compounds</u>								
SS: 1,2-Dichlorobenzene-d4	103		70-130		%Rec	1	07/06/2016 1:26 PM	R73718
SS: 4-Bromofluorobenzene	101		70-130		%Rec	1	07/06/2016 1:26 PM	R73718
VOLATILE ORGANIC COMPOUNDS (UNREGULATED)			Method: EPA-524.2-Rev 4.1, 1995			Analyst: rgb		
Methyl tert-butyl ether	ND		0.500		µg/L	1	07/06/2016 1:26 PM	R73718



Suburban Laboratories, Inc.

1950 S. Batavia Ave., Suite 150, Geneva, IL 60134 (708) 544-3260

Laboratory Results

Client ID: Sauk Village Water Department

Report Date: July 13, 2016

Project Name: Volatile Organic Compounds

Workorder: 1607093

Client Sample ID: TP02

Matrix: DRINKING WATER

Lab ID: 1607093-003

Date Received: 07/05/2016 4:40 PM

Collection Date: 07/05/2016 8:05 AM

Parameter	Result	Report MCL Limit	Qual.	Units	Dilution Factor	Date Analyzed	Batch ID
VOLATILE ORGANIC COMPOUNDS (REGULATED)		Method: EPA-524.2-Rev R4.1			Analyst: rgb		
Benzene	ND	5.00	0.500	µg/L	1	07/06/2016 1:54 PM	R73718
Carbon tetrachloride	ND	5.00	0.500	µg/L	1	07/06/2016 1:54 PM	R73718
Chlorobenzene	ND	100	0.500	µg/L	1	07/06/2016 1:54 PM	R73718
1,4-Dichlorobenzene	ND	75.0	0.500	µg/L	1	07/06/2016 1:54 PM	R73718
1,2-Dichlorobenzene	ND	600	0.500	µg/L	1	07/06/2016 1:54 PM	R73718
1,2-Dichloroethane	ND	5.00	0.500	µg/L	1	07/06/2016 1:54 PM	R73718
1,1-Dichloroethene	ND	7.00	0.500	µg/L	1	07/06/2016 1:54 PM	R73718
cis-1,2-Dichloroethene	ND	70.0	0.500	µg/L	1	07/06/2016 1:54 PM	R73718
trans-1,2-Dichloroethene	ND	100	0.500	µg/L	1	07/06/2016 1:54 PM	R73718
1,2-Dichloropropane	ND	5.00	0.500	µg/L	1	07/06/2016 1:54 PM	R73718
Ethylbenzene	ND	700	0.500	µg/L	1	07/06/2016 1:54 PM	R73718
Methylene chloride	ND	5.00	0.500	µg/L	1	07/06/2016 1:54 PM	R73718
Styrene	ND	100	0.500	µg/L	1	07/06/2016 1:54 PM	R73718
Tetrachloroethene	ND	5.00	0.500	µg/L	1	07/06/2016 1:54 PM	R73718
Toluene	ND	1,000	0.500	µg/L	1	07/06/2016 1:54 PM	R73718
1,2,4-Trichlorobenzene	ND	70.0	0.500	µg/L	1	07/06/2016 1:54 PM	R73718
Trichloroethene	ND	5.00	0.500	µg/L	1	07/06/2016 1:54 PM	R73718
1,1,1-Trichloroethane	ND	200	0.500	µg/L	1	07/06/2016 1:54 PM	R73718
1,1,2-Trichloroethane	ND	5.00	0.500	µg/L	1	07/06/2016 1:54 PM	R73718
Vinyl chloride	ND	2.00	0.500	µg/L	1	07/06/2016 1:54 PM	R73718
Total Xylenes	ND	10,000	0.500	µg/L	1	07/06/2016 1:54 PM	R73718
<u>Internal Quality Control Compounds</u>							
SS: 1,2-Dichlorobenzene-d4	109		70-130	%Rec	1	07/06/2016 1:54 PM	R73718
SS: 4-Bromofluorobenzene	105		70-130	%Rec	1	07/06/2016 1:54 PM	R73718
VOLATILE ORGANIC COMPOUNDS (UNREGULATED)		Method: EPA-524.2-Rev 4.1, 1995			Analyst: rgb		
Methyl tert-butyl ether	ND		0.500	µg/L	1	07/06/2016 1:54 PM	R73718